

ANALYTICAL REPORT

Job Number: 420-113608-1
SDG Number: Chester UFSD CES
Job Description: Orange-Ulster BOCES

For:
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Attention: Jack DeGraw



Meredith W Ruthven
Customer Service Manager
mruthven@envirotestlaboratories.com
12/13/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

Job Narrative
420-J113608-1

Comments

Results are compared to NYSDOH drinking water standards other federal regulations may apply.

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

Metals

No analytical or quality issues were noted.

METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-113608-1
SDG Number: Chester UFSD CES

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-113608-1
SDG Number: Chester UFSD CES

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Palentino, Gus J	GJP
EPA 200.8 Rev.5.4	Sirico, Derek	DS

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-113608-1
SDG Number: Chester UFSD CES

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-113608-1	CES Kitchen back prep sink by Microwave Retest	Drinking Water	11/23/2016 0555	11/23/2016 0907
420-113608-2	CES Kitchen Pot Filler Retest	Drinking Water	11/23/2016 0555	11/23/2016 0907
420-113608-3	CES Kitchen Back Wall Sink 1 Retest	Drinking Water	11/23/2016 0555	11/23/2016 0907
420-113608-4	CES Kitchen Back Wall Sink 2 Retest	Drinking Water	11/23/2016 0555	11/23/2016 0907
420-113608-5	CES Boys Locker Room Bath Sink Retest	Drinking Water	11/23/2016 0600	11/23/2016 0907
420-113608-6	CES Girls Locker Room Bath Sink 2 Retest	Drinking Water	11/23/2016 0601	11/23/2016 0907
420-113608-7	CES Main Office Kitchenette Retest	Drinking Water	11/23/2016 0603	11/23/2016 0907
420-113608-8	CES Nurse Sink 2 Retest	Drinking Water	11/23/2016 0604	11/23/2016 0907
420-113608-9	CES 114 Sink Retest	Drinking Water	11/23/2016 0604	11/23/2016 0907
420-113608-10	CES 114 Bubbler "Low" Retest	Drinking Water	11/23/2016 0605	11/23/2016 0907
420-113608-11	CES Kindergarten Section CR2 Sink Retest	Drinking Water	11/23/2016 0608	11/23/2016 0907
420-113608-12	CES Kindergarten Section CR2 Bubbler Low Retest	Drinking Water	11/23/2016 0609	11/23/2016 0907
420-113608-13	CES Kindergarten Section CR3 Sink Retest	Drinking Water	11/23/2016 0610	11/23/2016 0907
420-113608-14	CES Kindergarten Section CR3 Bubbler Low Retest	Drinking Water	11/23/2016 0610	11/23/2016 0907
420-113608-15	CES Kindergarten Section CR4 Bubbler Low Retest	Drinking Water	11/23/2016 0612	11/23/2016 0907
420-113608-16	CES 2nd Floor Faculty Room Mens Bath sink Retest	Drinking Water	11/23/2016 0614	11/23/2016 0907
420-113608-17	CES Rm 238-243 Bubbler 1 Retest	Drinking Water	11/23/2016 0615	11/23/2016 0907
420-113608-18	CES Rm 238-243 Bubbler 3 Retest	Drinking Water	11/23/2016 0615	11/23/2016 0907
420-113608-19	CES 2nd Floor Custodial Breakroom Sink Retest	Drinking Water	11/23/2016 0617	11/23/2016 0907
420-113608-20	CES 230 Elevator Side Sink 1 Retest	Drinking Water	11/23/2016 0620	11/23/2016 0907
420-113608-21	CES 230 Elevator Side Sink 2 Retest	Drinking Water	11/23/2016 0621	11/23/2016 0907
420-113608-22	CES Rm 130-136 Bubbler 3 Retest	Drinking Water	11/23/2016 0630	11/23/2016 0907

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Kitchen back prep sink by Microwave
Lab Sample ID: 420-113608-1

Date Sampled: 11/23/2016 0555
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/30/2016 1309	
Prep Method: 200			Date Prepared:	11/29/2016 1749	
Pb	12.0	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Kitchen Pot Filler Retest
Lab Sample ID: 420-113608-2

Date Sampled: 11/23/2016 0555
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/30/2016 1310		
Prep Method: 200			Date Prepared: 11/29/2016 1749		
Pb	84.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Kitchen Back Wall Sink 1 Retest
Lab Sample ID: 420-113608-3

Date Sampled: 11/23/2016 0555
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	12/02/2016 1206	
Prep Method: 200			Date Prepared:	12/01/2016 1000	
Pb	411 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Kitchen Back Wall Sink 2 Retest
Lab Sample ID: 420-113608-4

Date Sampled: 11/23/2016 0555
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/30/2016 1348		
Prep Method: 200			Date Prepared: 11/29/2016 1749		
Pb	41.2 g	ug/L	2.00	2.00	2.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Boys Locker Room Bath Sink Retest
Lab Sample ID: 420-113608-5

Date Sampled: 11/23/2016 0600
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/30/2016 1311		
Prep Method: 200			Date Prepared: 11/29/2016 1749		
Pb	436 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Girls Locker Room Bath Sink 2 Retest
Lab Sample ID: 420-113608-6

Date Sampled: 11/23/2016 0601
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/30/2016 1312		
Prep Method: 200			Date Prepared: 11/29/2016 1749		
Pb	68.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Main Office Kitchenette Retest
Lab Sample ID: 420-113608-7

Date Sampled: 11/23/2016 0603
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/30/2016 1313		
Prep Method: 200			Date Prepared: 11/29/2016 1749		
Pb	37.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Nurse Sink 2 Retest
Lab Sample ID: 420-113608-8

Date Sampled: 11/23/2016 0604
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/30/2016 1315		
Prep Method: 200			Date Prepared: 11/29/2016 1749		
Pb	16.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES 114 Sink Retest
Lab Sample ID: 420-113608-9

Date Sampled: 11/23/2016 0604
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/30/2016 1316		
Prep Method: 200			Date Prepared: 11/29/2016 1749		
Pb	28.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES 114 Bubbler "Low" Retest
Lab Sample ID: 420-113608-10

Date Sampled: 11/23/2016 0605
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/30/2016 1317		
Prep Method: 200			Date Prepared: 11/29/2016 1749		
Pb	4.09	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Kindergarten Section CR2 Sink Retest
Lab Sample ID: 420-113608-11

Date Sampled: 11/23/2016 0608
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/30/2016 1318		
Prep Method: 200			Date Prepared: 11/29/2016 1749		
Pb	62.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Kindergarten Section CR2 Bubbler Low
Lab Sample ID: 420-113608-12

Date Sampled: 11/23/2016 0609
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/30/2016 1318		
Prep Method: 200			Date Prepared: 11/29/2016 1815		
Pb	4.96	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Kindergarten Section CR3 Sink Retest
Lab Sample ID: 420-113608-13

Date Sampled: 11/23/2016 0610
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/30/2016 1321	
Prep Method: 200			Date Prepared:	11/29/2016 1815	
Pb	98.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Kindergarten Section CR3 Bubbler Low
Lab Sample ID: 420-113608-14

Date Sampled: 11/23/2016 0610
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/30/2016 1322		
Prep Method: 200			Date Prepared: 11/29/2016 1815		
Pb	9.70	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Kindergarten Section CR4 Bubbler Low
Lab Sample ID: 420-113608-15

Date Sampled: 11/23/2016 0612
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/30/2016 1324	
Prep Method: 200			Date Prepared:	11/29/2016 1815	
Pb	8.08	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES 2nd Floor Faculty Room Mens Bath sink
Lab Sample ID: 420-113608-16

Date Sampled: 11/23/2016 0614
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/30/2016 1325	
Prep Method: 200			Date Prepared:	11/29/2016 1815	
Pb	11.6	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Rm 238-243 Bubbler 1 Retest
Lab Sample ID: 420-113608-17

Date Sampled: 11/23/2016 0615
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/30/2016 1326	
Prep Method: 200			Date Prepared:	11/29/2016 1815	
Pb	79.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Rm 238-243 Bubbler 3 Retest
Lab Sample ID: 420-113608-18

Date Sampled: 11/23/2016 0615
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/30/2016 1327	
Prep Method: 200			Date Prepared:	11/29/2016 1815	
Pb	33.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES 2nd Floor Custodial Breakroom Sink
Lab Sample ID: 420-113608-19

Date Sampled: 11/23/2016 0617
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/30/2016 1328		
Prep Method: 200			Date Prepared: 11/29/2016 1815		
Pb	155 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES 230 Elevator Side Sink 1 Retest
Lab Sample ID: 420-113608-20

Date Sampled: 11/23/2016 0620
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/30/2016 1328	
Prep Method: 200			Date Prepared:	11/29/2016 1815	
Pb	4.58	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES 230 Elevator Side Sink 2 Retest
Lab Sample ID: 420-113608-21

Date Sampled: 11/23/2016 0621
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/30/2016 1329	
Prep Method: 200			Date Prepared:	11/29/2016 1815	
Pb	12.6	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-113608-1
Sdg Number: Chester UFSD CES

Client Sample ID: CES Rm 130-136 Bubbler 3 Retest
Lab Sample ID: 420-113608-22

Date Sampled: 11/23/2016 0630
Date Received: 11/23/2016 0907
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/30/2016 1330	
Prep Method: 200			Date Prepared:	11/29/2016 1815	
Pb	132 g	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:
Sdg Number: Chester UFSD CES

Lab Section	Qualifier	Description
Metals	g	Result fails applicable NYS drinking water standards

Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Chester UFSD CES

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalein Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Chester UFSD CES

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.



CHAIN OF CUSTODY

REPORT# (Lab Use Only)
113608

EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

Lab Name
Address & Phone

PROJECT REFERENCE Chester UFSD CES	PROJECT NO.	PROJECT LOCATION Chester	PAGE 1 of 1
ENVIROTEST PROJECT MANAGER Debra Bayer	PO NUMBER	TOWN Chester NY	TURNAROUND TIME
CLIENT SITE/PM Jack DeGraw	CLIENT PHONE 845-781-4887	CLIENT FAX	
CLIENT NAME Orange-Ulster BOGES	Please Email Results to: christy.fischer@oubores.org		
CLIENT ADDRESS 93 Gibsom Road, Goshen, NY 10924			
COMPANY CONTRACTING THIS WORK (if applicable)			

DATE	TIME	SAMPLE IDENTIFICATION	REQUIRED ANALYSES										OTHER	REMARKS		
			40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	Other				
11/23/16	555	CES Kitchen back prep sink by Microwave Retest	1													Lead (DW 200.8)
11/23/16	555	CES Kitchen Pot Filler Retest	1													Lead (DW 200.8)
11/23/16	555	CES Kitchen Back Wall Sink 1 Retest	1													Lead (DW 200.8)
11/23/16	555	CES Kitchen Back Wall Sink 2 Retest	1													Lead (DW 200.8)
11/23/16	600	CES Boys Locker Room Bath Sink Retest	1													Lead (DW 200.8)
11/23/16	601	CES Girls Locker Room Bath Sink 2 Retest	1													Lead (DW 200.8)
11/23/16	603	CES Main Office Kitchenette Retest	1													Lead (DW 200.8)
11/23/16	604	CES Nurse Sink 2 Retest	1													Lead (DW 200.8)
11/23/16	604	CES 114 Sink Retest	1													Lead (DW 200.8)
11/23/16	605	CES 114 Bubbler "Low" Retest	1													Lead (DW 200.8)
11/23/16	608	CES Kindergarten Section CR2 Sink Retest	1													Lead (DW 200.8)
11/23/16	609	CES Kindergarten Section CR2 Bubbler Low Retest	1													Lead (DW 200.8)
11/23/16	610	CES Kindergarten Section CR3 Sink Retest	1													Lead (DW 200.8)
11/23/16	610	CES Kindergarten Section CR3 Bubbler Low Retest	1													Lead (DW 200.8)
11/23/16	612	CES Kindergarten Section CR4 Bubbler Low Retest	1													Lead (DW 200.8)
11/23/16	614	CES 2nd Floor Faculty Room Mens Bath Sink Retest	1													Lead (DW 200.8)
11/23/16	615	CES Rm 238-243 Bubbler 1 Retest	1													Lead (DW 200.8)
11/23/16	615	CES Rm 238-243 Bubbler 3 Retest	1													Lead (DW 200.8)
11/23/16	617	CES 2nd Floor Custodial Breakroom Sink Retest	1													Lead (DW 200.8)
11/23/16	620	CES 230 Elevator Side Sink 1 Retest	1													Lead (DW 200.8)
11/23/16	621	CES 230 Elevator Side Sink 2 Retest	1													Lead (DW 200.8)
11/23/16	630	CES Rm 130-136 Bubbler 3 Retest	1													Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
<i>[Signature]</i>	11/23/16	4:07	<i>[Signature]</i>		
SAMPLED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
<i>[Signature]</i>	11/23/16	5:10	<i>[Signature]</i>		
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
<i>[Signature]</i>			<i>[Signature]</i>		

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	COOLER TEMP (C)	LABORATORY REMARKS
<i>[Signature]</i>	11/23/16	5:10	YES	18.0	ICE (Y/N) / pH / CL2

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-113608-1
SDG Number: Chester UFSD CES

Login Number: 113608

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	18.0 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	